

Automation, Logic and Time Control

Although the network is connected to the ABA/S 1.2.1 the download runs over KNX-USB and thus very slow. What can be the reason for that?

1. 1. Check network settings!
2. 2. Check the ETS connection settings. The parameter “**Use direct IP connection if available**“ has to be selected.
3. ETS4:
4. 

5. ETS5:
6. 

Unique solution ID: #1281
Author: Carolina Bachenheimer-Schaefer
Last update: 2016-11-21 16:03

(c) 2024 ABB AG <knx.helpline@de.abb.com> | 19.03.2024 08:32
URL: https://faq.abb-buildingautomation.com/index.php?action=artikel&cat=39&id=281&artlang=en