Energy Management

Which language is basically set after first commissioning of the QA/S x.x.1?

The language will be adjust dependent on the settings of the used web browser.

Unique solution ID: #1517
Author: BA Engineering Team
Last update: 2020-10-21 09:18

(c) 2024 ABB AG <knx.helpline@de.abb.com> | 28.03.2024 14:29
URL: https://faq.abb-buildingautomation.com/index.php?action=artikel&cat=43&id=517&artlang=en