Heating, Ventilation and Air Conditioning

Does the limitation of the temperature range from the SUG/U 1.1 have an effect on the cyclic sending for positioning?

Yes, is e.g. the limitation min. 23 °C for cooling and max. 29 °C for heating, the telegrams for 21 °C and 22 °C have no effect.

Unique solution ID: #1439
Author: Kevin Klemm
Last update: 2017-08-28 15:15

(c) 2024 ABB AG <knx.helpline@de.abb.com> | 29.03.2024 05:40
URL: https://faq.abb-buildingautomation.com/index.php?action=artikel&cat=44&id=439&artlang=en