

Heating, Ventilation and Air Conditioning

How to handle a Split Unit which is not in the database of the split unit gateway SUG/U 1.1?

We need the manufacturer of the Split Unit and the type of the remote control. The remote control is needed physically to read out the individual IR code. We are interested in extending the database with missing IR codes. Please come back to us to implement it.

Unique solution ID: #1494

Author: Carolina Bachenheimer-Schaefer

Last update: 2017-09-20 10:36