

Power Supply

When and how must Battery Modules AM/S 12.1 be maintained?

We suggest testing the Battery Modules yearly, so that the power failure buffering time can always be ensured.

Maintenance can be performed to the effect that during the switch-off of the mains voltage, different functions are tested on the actual Power Supply, e.g. transmission of fault messages.

We also suggest documenting the corresponding maintenance intervals.

Unique solution ID: #1162

Author: Carolina Bachenheimer-Schaefer

Last update: 2016-10-05 11:46