

IP-Router and Interfaces

Can an IP Gateway IG/S 1.1 be programmed with the EIBLIP protocol using the ETS 5?

Using the standard function of the Falcon driver, the IG/S 1.1 cannot be programmed via IP in the ETS 5. Logging of telegrams on the IP side is also not possible. The ETS 5 supports only the KNXNetIP protocol standard. In the KNX App Store, you can acquire an app that still supports the old EIBLIP protocol as well. Please see your online KNX account for more information.

Unique solution ID: #1198

Author: Carolina Bachenheimer-Schaefer

Last update: 2016-10-06 10:21