

Outdoor Stations

Welcome outdoor station: if there is a high rise building installation and there is a trigger of the binary input for magnetic door contact (door status check), which indoor station will the alarm be display?

The alarm signal will be send to all indoor station and guard units within the high rise building installation, the LED status of the door unlock button will flash.

For more information, please check our System

Manual:

https://library.e.abb.com/public/298d6c313822445584beea5e6fbcdd1/2TMC107015M0201_WelcomeSystemManual.pdf

Unique solution ID: #1288

Author: Carolina Bachenheimer-Schaefer

Last update: 2016-12-07 12:22