

# Automation, Logic and Time Control

## Can data from an AB/S 1.1 be adopted in an ABL/S 2.1?

It is possible to transfer project data out of an AB/S 1.1 into an ABL/S 2.1. The prerequisite for this is that the data from AB/S 1.1 was already converted for the application version 1.4. The AB/S data in the ABL/S can then be converted in the ABL/S 2.1 plug-in "**Import from logic time 200 EA**". The ABL/S plug-in lists all AB/S devices for which conversion is possible.

Unique solution ID: #1174

Author: Carolina Bachenheimer-Schaefer

Last update: 2016-10-05 14:06