

Heating, Ventilation and Air Conditioning

Why does the air quality sensor LGS/A 2.1 show different values than my measuring device?

Please check that both devices measure in the exact same spot in the room. Also be sure that there is no air flow in the room, e.g. because of a open window or door.

Unique solution ID: #1296

Author: Carolina Bachenheimer-Schaefer

Last update: 2017-12-05 13:29