

Heating, Ventilation and Air Conditioning

SUG/U 1.1: Is it possible to parametrize the minimum setpoint for "cooling" greater than the maximum setpoint for "heating"?

It is, in this case the "area" of the limitation is in fact the maximum temperature setpoint.

Unique solution ID: #1441

Author: Kevin Klemm

Last update: 2017-08-28 15:31