

Heating, Ventilation and Air Conditioning

Does the SUG/U 1.1 react to KNX switching commands during the timer delay for the window contact?

Yes, it won't react to commands after the timer for the "On/Off delay" function is expired.

Unique solution ID: #1443

Author: Kevin Klemm

Last update: 2017-08-28 15:44