

Heating, Ventilation and Air Conditioning

Will the status of a non-supporting functionality from the SUG/U 1.1 be evaluated and additionally be sent to the bus?

No, please have a look inside the ETS App (ABB SUG/U1.1 Configuration App) or the i-bus tool. The supported features are listed there.

Unique solution ID: #1444

Author: Kevin Klemm

Last update: 2017-08-28 15:48