

# Heating, Ventilation and Air Conditioning

## FCA/S 1.x.x.2: Which types of valve drives can be connected and how many of them?

### FCA/S 1.1.x.2

The fan coil Actuator has separate output for:

- Magnetic valve drives (On/Off): 4
- thermoelectric valve drives (PWM): 4
- Motoric 3-Point valve drives (Open/Close): 4
- Motoric 0-10V valve drives (0-10V): 0

### FCA/S 1.2.x.2

The fan coil Actuator has separate output for:

- Magnetic valve drives (On/Off): 0
- thermoelectric valve drives (PWM): 0
- Motoric 3-Point valve drives (Open/Close): 0
- Motoric 0-10V valve drives (0-10V): 2

Unique solution ID: #1486

Author: Marcel Feuerstein

Last update: 2017-09-18 09:59