

Heating, Ventilation and Air Conditioning

Can I still use the Split Unit remote control when using the Split Unit Gateway SUG/U 1.1?

Yes, you can. If you use it in parallel, the status on KNX might not be correct anymore. Next time you send any KNX command (e.g. on/off, recall of scene, change of set point, ...) all status will be correct again.

Unique solution ID: #1490

Author: Carolina Bachenheimer-Schaefer

Last update: 2017-09-20 16:07