

# Heating, Ventilation and Air Conditioning

## In the application of the split unit gateway SUG/U 1.1 there is a group object called 'request status value', what does it mean?

If you send value 1 on this, all status values that are enabled will be sent on KNX.

Unique solution ID: #1493

Author: Carolina Bachenheimer-Schaefer

Last update: 2017-09-20 10:35