

Heating, Ventilation and Air Conditioning

Is there any logic in the air quality sensor LGS/A 1.2 e.g. to control VAV damper via the highest value of CO2 or room temperature?

There is no logic in the LGS/A 1.2 to link room temperature with CO2 control. For this an additional KNX device would be necessary (e.g. Logic Controller ABA/S)

Unique solution ID: #1518

Author: Carolina Bachenheimer-Schaefer

Last update: 2017-12-05 13:30