

# Heating, Ventilation and Air Conditioning

## Is it possible to have an additional room controller as a slave together with the air quality sensor LGS/A 1.2?

For adjustments by the user it is possible to assign an additional room temperature controller as a slave. The temperature is controlled by the LGS/A as the master. In the ETS application either the function master or single device can be selected. The air quality sensor LGS/A 1.2 is using the unified RTC concept from ABB, for an easy implementation of master-slave functionality.

Unique solution ID: #1520

Author: Carolina Bachenheimer-Schaefer

Last update: 2017-12-05 13:34