

Heating, Ventilation and Air Conditioning

FCC/S 1.x.x.1: Is it allowed that the setpoint temperature for heating and cooling are the same value?

No, this is not possible and a wrong parameterization as well. The setpoint temperature for cooling must be set higher than the setpoint temperature for heating.

If you want to use the same setpoint for both, heating and cooling, you can set this in the parameters.

Comfort heating setpoint = Comfort cooling setpoint No Yes

Unique solution ID: #1571
Author: Marcel Feuerstein
Last update: 2018-07-09 14:12