

# Heating, Ventilation and Air Conditioning

## **FCC/S 1.x.x.1: What should be considered if the temperature is received via physical device input and via group object as well?**

The weighting of external and internal measurement is important and can be set in the parameters. You can find examples in the product manual.

### **Note:**

**With this setting at least one temperature sensor must be connected to the physical device input so that the internal controller can evaluate the combination of external and internal measurement.**

Unique solution ID: #1578

Author: Marcel Feuerstein

Last update: 2018-07-05 13:43