

Heating, Ventilation and Air Conditioning

Is it possible to connect the analog room control unit to any input of the FCC/S 1.x.x.1?

No, this is not possible. As mentioned in the application only the “input a” is available for setpoint adjustment via room control unit.

Unique solution ID: #1579

Author: Marcel Feuerstein

Last update: 2018-07-05 13:44