

# **Heating, Ventilation and Air Conditioning**

## **Since the BAC/S1.5.1 has an integrated Modbus RS485 interface is it possible to connect energy meters?**

Yes, the connection of Modbus Energy Meters is possible.

Unique solution ID: #1600

Author: Johanna Feindler

Last update: 2018-12-13 11:34