

Heating, Ventilation and Air Conditioning

Are the KNX variables automatically mapped as Modbus registers?

No, you have to create an automation program which implements the communication between the interfaces.

Unique solution ID: #1606

Author: Johanna Feindler

Last update: 2018-12-13 11:31