

Heating, Ventilation and Air Conditioning

Are the linked KNX Group Addresses kept in ETS when you run a new import from Automation Builder?

Yes, the DCA Automation Builder has a versions management implemented. Already linked Group Addresses are kept. Even if you change the name of the KNX Group Object.

Unique solution ID: #1610

Author: Johanna Feindler

Last update: 2018-12-13 11:18