

Heating, Ventilation and Air Conditioning

HCC/S 2.x.x.1: Why is there no communication object provided for the current time and day of the week when the "double pump mode" is activated?

The current time is only relevant to the HCC/S if the operating mode of the pump is set to "Change weekly".

Unique solution ID: #1639

Author: Marcel Feuerstein

Last update: 2019-02-12 14:40