Heating, Ventilation and Air Conditioning HCC/S 2.x.x.1: How is the duration of the valve purge calculated?

During the purge the valve gets completely opened and closed, so the double time is used for the total duration according to the deposited times in the parameters.

General	Valve output	Activated Deactivated	
+ Manual operation	Voltage range valve control value	0 - 10 V	•
- Channel A	Valve drive opening/closing time	180	÷ S
General	Valve output	Motor-driven (3-point)	
- Channel A	Output B is used for the 'Open' signal, output C for the 'Close' signal		
	Reversing time	500	‡ ms
Application parameters	Switch on time for valve drive from 0 to 100%	120	÷ 5

Unique solution ID: #1640 Author: BA Engineering Team Last update: 2019-02-14 10:44