

Heating, Ventilation and Air Conditioning

Is it possible to control heating and cooling application within one channel of the HCC/S 2.x.x.1?

No, because there is only one controller per channel. To switch between heating and cooling the associated KNX communication object has to be used.

65 Channel A - Controller Heating/Cooling changeover 1 bit C - W T U cooling/heating

Unique solution ID: #1641
Author: BA Engineering Team
Last update: 2019-02-14 10:45