

Heating, Ventilation and Air Conditioning

HCC/S 2.x.x.1: What significance does the supply flow temperature have in the device function "actor device"?

In this function, the measured supply flow temperature has no effect on the HCC/S. It can only be used to display and sent to an external controller.

Unique solution ID: #1642

Author: Marcel Feuerstein

Last update: 2019-02-12 15:47