

Heating, Ventilation and Air Conditioning

What are the limitations (group objects, ASM´s, etc.) of the AC/S 1.x.1?

The limits can be shown within DCA by using the function "Run project verification".



	Current	Maximum
ASMs used	12	500
KNX group objects used	34	2000
BACnet objects used	2	500
ASM Schedules count	2	15
Central HVAC, ASM count	3	15
ASM Trend count	0	50

Unique solution ID: #1680
Author: BA Engineering Team
Last update: 2019-04-04 14:30