

Heating, Ventilation and Air Conditioning

Is it possible to operate the FCC/S 1.x.x.1 together with the ClimaECO sensor SBx/U x.0.11-84 in the master/slave concept?

Yes, it is possible. It is important to pay attention to the correct parameter settings as well as links of the corresponding KNX communication objects of the two devices.

The following exemplary functional instructions on our Engineering Guide Database helps to implement this in the ETS:

[Link to the document](#)

[Engineering Guide Database](#)

Unique solution ID: #1685
Author: BA Engineering Team
Last update: 2019-07-04 09:34