

# Heating, Ventilation and Air Conditioning

## Can the FCC/S 1.x.x.1 be used to implement a single room control and what do you have to consider?

Yes, that is possible. For this purpose, an analog room control unit (SAR/A 1.0.1 or SAF/A 1.0.1) can be connected to the Fan Coil Controller.

How to do:

[Link to the document](#)

[Engineering Guide Database](#)

Unique solution ID: #1686  
Author: BA Engineering Team  
Last update: 2019-07-04 09:35