

Heating, Ventilation and Air Conditioning

Does the FCC / S 1.x.x.1 also support the operation of a 6-way valve?

Yes it does. The parameter settings in the ETS can be used to implement this operation.

Important information can be found in our Engineering Guide Database:

[Link to the document](#)

[Engineering Guide Database](#)

Unique solution ID: #1690

Author: BA Engineering Team

Last update: 2019-08-01 11:35