

Lighting Control

Can the lux values measured by Light Sensor LF/U be displayed directly?

The LF/U itself is not an independent KNX device. It works only in connection with ABB i-bus KNX Light Controllers. For these Light Controllers, the ABB i-bus Tool can display the measured values. The measured values are not, however, made available as lux values (DPT 9.003) over the KNX bus, because the measured values are required only for internal processing in the Light Controllers.

Unique solution ID: #1172

Author: Carolina Bachenheimer-Schaefer

Last update: 2016-10-05 13:52