

Room Management

Can you convert the Room Controller RC/A 8.1 into RC/A 8.2?

During replacement of an RC/A 8.1 with the successor RC/A 8.2, the existing parameterization can be adopted or converted. The application program of the RC/A 8.2 - V 1.0a includes a conversion function. The conversion function serves for adoption of parameters and group addresses in an ETS project. Starting with this version 1.0a, the parameters and group addresses of Room Controller RC/A 8.1 can be adopted. This can be used, for example, to replace the RC/A 8.1 with an RC/A 8.2 in an existing ETS project.

Unique solution ID: #1164

Author: Carolina Bachenheimer-Schaefer

Last update: 2017-02-09 12:15