User Operation - Tacteo

Can an MT 701 be reconstructed?

No, it cannot be reconstructed. This function is also not supported with the plug-in anchored in the ETS.

Unique solution ID: #1177
Author: Carolina Bachenheimer-Schaefer
Last update: 2016-10-05 14:23

(c) 2024 ABB AG <knx.helpline@de.abb.com> | 29.03.2024 11:20

URL: https://faq.abb-buildingautomation.com/index.php?action=artikel&cat=145&id=177&artlang=en