Visualisation, Display and Signalling

Can an MT 701 that was generated with EIBTAB also be edited in the ETS plug-in?

No, both product data sets are mutually incompatible. The ETS plug-in can be used only for the MT 701.2.

Unique solution ID: #1182
Author: Carolina Bachenheimer-Schaefer
Last update: 2016-10-06 09:31

(c) 2024 ABB AG <knx.helpline@de.abb.com> | 28.03.2024 14:46
URL: https://faq.abb-buildingautomation.com/index.php?action=artikel&cat=147&id=182&artlang=en