

# **Safety and Security**

## **When must batteries in the safety equipment be maintained or changed?**

According to VdS, the batteries in the safety equipment must be completely changed every four years.

Furthermore, the batteries must be maintained at yearly intervals. This should be coordinated with the maintenance interval of the alarm system, so that the voltage can be turned off during the interval.

Unique solution ID: #1245

Author: Carolina Bachenheimer-Schaefer

Last update: 2016-10-06 12:12